

Ver. 1.09 (Release Date: 12/09/2016):

New Feature

- Three Phase Tower UPS and Three Phase Modular UPS support

Bug Fixed

- Fixed the detection function while utility frequency out of range.
- Fixed the issue that system could not login when using MAC Safari.
- Fixed the mis-sending in Bank Overload Event to PPBE Center when RMCARD lost the communication with ATS.
- Fixed the mis-sending in Login Event when testing LDAP and RADIUS.
- Fixed being unable to authenticate for the change of verification method in Google email.
- Regulated the Battery Replacement Date setting for particular PR UPS Models.
- Regulated the expired date of battery for particular PR UPS Models.
- Fixed the incorrect type of UPS MIB (RFC1628) OID.

Ver. 1.08 (Release Date: 11/04/2016):

New Feature

- Force user to change the default username/password upon first login.

Feature Improved

- Increase the SSH certificate compatibility.
- Increase the SMTP certificate compatibility.
- The Web Interface is modified in words.

Bug Fixed

- Fixed SNMP communication when more than one user set the same community but with different IP addresses.
- Fixed the system not sending the login fail event when user's IP not matching with manager IP.
- Fixed Battery Voltage Rating display when UPS have 4 internal battery packs.

- Fixed SNMP communication being failing after use OID to reset RMCARD.

Ver. 1.07 (Release Date: 08/08/2016):

Bug Fixed

- Fixed the issue of being unable to log in after changing the admin user password.

Ver. 1.06 (Release Date: 07/12/2016):

Feature Improved

- Display UPS Serial Number information at the UPS Detail Information field on the PPBE Center user interface.

Bug Fixed

- Fixed the Save and Restore Configuration about event action.
- Fixed the issue about Next Replacement Date setting.
- Fixed the issue about UPS battery test result display on the PPBE Center user interface.
- Fixed the issue about ATS administrator having insufficient control permissions by external authentication after an ATS outlet user logs out.

Ver. 1.05 (Release Date: 04/26/2016):

New Feature

- Google Gmail authentication interface.

Feature Improved

- Allow outlet user to log in with RADIUS/LDAP.
- Allow two decimal digits displayed for Electricity Rate.
- Modified the display content of webpage.

Bug Fixed

- Fixed the issue about daylight saving time setting.
- Fixed the issue about RADIUS feature being unable to create.
- Fixed the issue about Command line interface feature being unable to work on certain conditions.

Ver. 1.04 (Release Date: 03/11/2016):

New Feature

- Command line interface feature.

Feature Improved

- SSH remove MD5. (Security vulnerability consideration)
- Add Event about UPS Battery Replace.
- Allow users set account and password with all special characters.
(eg. !@#\$%^&*)
- Increase the SNMP trap compatibility.

Bug Fixed

- Fixed the issue about Australian daylight saving time setting.
- Fixed the inappropriate display for “NCL off delay” for particular UPS models.
- Fixed the bug while using SNMP to get “upsBaseIdentModel” and “sysObjectID”.

Ver. 1.03 (Release Date: 12/10/2015):

Bug Fixed

- Environmental Sensor was unable to work with RMCARD305.
- Fixed the issue that the setting could not work if Manager IP without subnet mask.
- Fixed the issue that the system could not login when Manager IP used Ipv6 subnet mask setting which was not a multiple of 4.
- Fixed the inappropriate display for battery replace date on UI for particular UPS models.

Ver. 1.02 (Release Date: 11/18/2015):

New Feature

- Add support ATS 32A feature.

Feature Improved

- SSL remove RC4 related cipher suites. (Security vulnerability consideration)
- Using the cross-network segment by PPBE can access control RMCARD.

Bug Fixed

- Fixed the issue about Manager IP by subnet mask feature unable to work.
- Fixed RMCARD and PPBE sync related issue, including Periodical Battery Test and NCL Turn Off Delay.
- Fixed Outlet User related issue, including user account, logout event, auto login and webpage identity display.
- Fixed the issue about RMCARD NCL Bank setting and display unable to be synchronized.

Ver. 1.01 (Release Date: 09/30/2015):

New Feature

- Configurable System Date Format.
- For OL Series UPS, users can configure exclusive days of week and a period of time when selecting ECO mode.
- Users can set Manager IP by subnet mask.

Feature Improved

- Added retry mechanism on WOL function.
- Modified the input field of system date to Drop-Down Menu format.
- German grammar correction.
- French grammar correction.

Bug Fixed

- Expanded the compatibility for uploading certificate for SSL/SSH.

- Fixed the bug about DHCP being disabled occasionally when syslog enabled.
- Fixed UPS sleep function compatibility issues.

Ver. 1.00 (Release Date: 08/03/2015):

- First Release.